

Water Manager Report March 14, 2022 to May 8, 2022

Mar. 14

Ron Akey and Dean Kuns moved rock with the backhoe to make room for the final section of the Price Line to the block tank.

Mar. 15

Bob Mooney, Ron Akey and Dean Kuns
Moved rocks and leveled the ground.

Mar. 16

Bob Mooney, Ron Akey and Dean Kuns repaired a leak that was up inside the 5" iron pipe.

Mar. 18

Dean Kuns leveled ground and adjusted iron pipe and cleared bushes.

Mar. 28

Doug Clark, Gunnar Ramstrum, Bob Mooney, Jerry Bucheit and Dean Kuns began digging the trench for the final section to the block tank.

Mar. 30

Ron Akey, Doug Clark, Gunnar Ramstrum, Bob Mooney, Jerry Bucheit and Dean Kuns continued digging the trench and removed the large valve.

Mar. 31

Ron Akey, Doug Clark, Gunnar Ramstrum, Bob Mooney, Jerry Bucheit and Dean Kuns finished the trench, laid out the pipe and cleared the area in preparation to lay pipe.

Apr. 1

Tom Stucke, Jerry Bucheit, Gunnar Ramstrum Ron Akey, Doug Clark and Dean Kuns laid the final section of pipeline to the block tank.

Apr. 2

Bob Mooney, Jerry Bucheit, Ron Akey and Dean Kuns started filling in the trench and hauled away the old pipe.

Apr. 5

Bob Mooney, Jerry Bucheit, Frank Colver and Dean Kuns finished filling in the trench, cleaned up the area and moved the remaining 3" pipe to storage.

Apr. 6

Jerry Bucheit and Dean Kuns took water samples

Apr. 9

Dean Kuns went to El Centro for fuel.

Apr. 13

Dean Kuns adjusted sleeves and strapped pipe.

Apr. 14

Dean Kuns leveled and strapped the pipe.

May 6

Dean Kuns removed a piece of pipe sticking up in Canebrake Road near Staghorn Road

May 8

I was informed there was water running at a house and the owner had left for the summer.

I went and checked on it and found the shut off valve at the meter is leaking through with the value off. This leak is so slight it doesn't register on the meter.