

CANEBRAKE COUNTY WATER DISTRICT
WATER MANAGER REPORT
MAY 12 - JUNE 11, 2020

May 12 - Dean assembled fire hydrant. .5 hr.

May 15 - Dean & Jerry worked on pipeline. 5 hrs.

May 16 - Dean & Jerry worked on pipeline.

May 19 - Dean , Jerry & Ron Set up portable water tanks for backup water supply. 5 hrs.

May 20 - Dean , Jerry , Pete & Jim Swabbed the pipe with chlorine. Bob & Rob joined us and we assembled first section of pipeline. Thanks to Donna for pictures and Thanks to Hank for lunch.

May 21 - Dean & Jerry repaired a leak where the new 3" meets the old 2" then took water samples. 2 hrs. Thanks to Kathy for finding the leak.

May 24 - Dean & Mike found a leak near the 2" to 3" connection Caused by the pipeline shifting. We repaired the leak and braced the pipeline. 2.5 hrs.

May 26 - Dean started covering new pipeline. 2 hrs.

May 28 - Dean covered more pipeline. 2.5 hrs.

May 29 - Dean & Jerry tried to move the portable water tanks and blew out two tires

June 1 - Dean & Ron blocked up the portable tank trailer and loosened the tire lugs getting it ready to change the tires. Watered some plants at the community center to lower the water level in tanks. 2 hrs.

June 4 - Dean, Jerry , Ron & David from Majestic Pines Water District. We added chlorine to the round and block tanks.

June 5 - Dean, Jerry & Ron watered plants at the community center and opened blow offs to pull the treated water into the system. 4 hrs.

June 6 - We found we had left a hose running at the community center. Dean & Jerry opened blow offs and fire hydrants to flush the treated water from the system. 5 hrs.

June 7 - Dean & Jerry continued to use blow offs & fire hydrants to flush treated water and air from the system. Worked from canyon to the lowest points twice until there was no smell or taste of chlorine in the water. 8 hrs.

June 8 - Dean & Jerry checked the cleanliness of the block tank then turned on Peterson well to begin filling the block tank. We checked the pipeline behind Alexanders and found a small leak. We repaired the leak with no loss of water to customers. 2.5 hrs.

June 9 - Dean turned on Peterson well to continue filling the block tank. Dean & Jerry took water samples. 1.5 hrs.

June 10 - Dean went to El Centro for fuel, 35 gallons of gas. Received results of water test negative on both E-coli and Coliform.

June 11 - Dean ran Peterson well for 30 minutes to flush off the surface of the block tank.