

Water Manager Report June 8, 2024 by Deans Kuns

May 13

Jerry Bucheit and Dean Kuns

Repaired a leak at the top of upward Trail

Replaced a section of poly pipe with PVC.

May 29

Jerry Bucheit and Dean Kuns

Repaired a leaking fire hydrant on

Canyon Road.

It had a cracked fitting.

We replaced the fitting and replaced
the 3/4" valve with a 2" valve.