



Ellyn Hae <recyclingbynature@gmail.com>

CCWD Water Manager Report Mar. 11 2023

1 message

Dean Kuns <sardean001@gmail.com>

Fri, Mar 10, 2023 at 1:56 PM

To: Jerry Bucheit <bucheitjerry@gmail.com>

Cc: Jean Sturges <jeanstur45@att.net>, Gunnar Ramstrum <gunnar.ramstrum@gmail.com>, Ellyn Hae <recyclingbynature@gmail.com>

Jan. 16

Ron Akey , Bob Mooney , Jerry Bucheit

Tom Stucke , Gunnar Ramstrum and

Dean Kuns

Started preparation on the pad for the new tank.

Jan. 17

Bob Mooney , Jerry Bucheit ,

and Dean Kuns

Finished leveling the pad for the new tank.

Jan. 19

Went to El Centro to get parts to hook up the new tank.

Jan. 21

The new tank was delivered and with the help of all the great volunteers was set in place.

A big Thank You !!!

To everyone that showed up to help.

Jan. 22

Jerry Bucheit and Dean Kuns

Installed shoring boards next to the pad for the new tank.

Feb. 10

Bob Mooney , Jerry Bucheit and Dean Kuns

Met with Janelle Mc Cullough from DEH

at the new tank to discuss the code requirements to install and hook up the new tank.

Feb. 19

Ran Peterson well to raise the level of the round tank.

Feb. 20

Bob Mooney , David Mooney , Jerry Bucheit

Ron & Bonnie Akey , Mike Hammond ,

and Dean Kuns

And Thanks to Natalie Spandau for pictures.

Cleared weeds from around Peterson well and the round tank.

Feb. 23

Went to El Centro to get fuel.

Feb. 28

Read meters.

Mar. 6

Bob Mooney and Dean Kuns
Went to El Centro to pick up the work truck
and some pipe and fittings.
Filled the truck with fuel.

Mar. 8

Ran the Peterson well to raise the level of
the round tank.

Mar. 9

Had a drop in the round tank.
Natalie Spandau and Dean Kuns
Starting looking for a leak.
We found a leak by the corner
near the mail boxes.
Turned off the nearest valve
repaired the leak turned the water
back on and ran the Peterson well
to raise the level of the round tank.

Mar. 10

Ran Peterson well to raise the level of
the round tank.
Thanks to
Chris Macdonald ,Gunnar Ramstrum
For clearing brush from around
Mooney well.