

Canebrake County Water District
Water Manager's Report
November 14, 2020

Sep. 17 - 2020

Dean Kuns

Ran Peterson well 5 hrs. to bring block tank up before switching to round tank.

Sep. 18 - 2020

Dean Kuns

Switched to round tank.

Sep. 26 - 2020

Dean Kuns

Ran Peterson well 6 hrs. to bring up round tank due to high usage.

Oct. 17 - 2020

Dean Kuns

Switched to block tank.

Oct. 22 - 2020

Dean Kuns

Switched to round tank.

Oct. 24 - 2020

Dean Kuns

Repaired leak near meter # 31. Removed the damaged pipe and replaced it.

Oct. 25 - 2020

Dean Kuns

Ran Peterson well 4 hrs. due to leak and high usage.

Oct. 31 - 2020

Dean Kuns, Ron Akey, Daryl Holmes Sr. and Daryl Holmes Jr.

Did meter readings. Thank you for the help gentlemen!!!

Nov. 3 - 2020

Dean Kuns

Ran Peterson well 6 hrs. due to high usage.

Nov. 9 - 2020

Dean Kuns

Replaced batteries and reset timer on Peterson well and reset timer on Mooney well due to power outage.

Nov. 10 - 2020

Dean Kuns

Ran Peterson well 8 hrs. due to power outage. Mooney well missed 1 cycle and Peterson well missed 2 cycles.

Nov. 11 - 2020

Switched to block tank.

Nov. 12 - 2020

Dean Kuns

Switched back to round tank due to possible contamination in block tank.

Dean Kuns

Removed the old pipe from Carl McKenney's property.

Nov. 13 - 2020

Dean Kuns

After closer inspection two bees were removed from the tank. Switched back to block tank and ran Peterson well 3 hrs. to flush surface of block tank.

Dean Kuns

Repaired a leak near meter # 62 replaced the washer between the valve and the meter.

CCWD Water Manager

Dean Kuns