

Water Manager Report May 11, 2024 by Deans Kuns

A big Thank You to Bill Dimmock
For all the great work he did on
the vault and cage to cover the
valves at the poly tank.

Mar. 10

Dean lowered the water sample
Valve at the poly tank so
the cage would fit.

Mar. 11

Gunnar Ramstum and Dean Kuns
Took the quarterly water sample.

Mar. 23

Gunnar Ramstum , Steve Fillmore,
Chris Macdonald, Mike Hammond
and Tom Stucke
Installed an automated level reader
on the steel tank.

Mar. 29

Tom Stucke, Ron Akey, Steve Fillmore,
Daryl Holmes Jr , Chris Macdonald ,
Gunnar Ramstum, Mike Hammond
and Dean Kuns
Cleaned out the vaults and dug down
to expose the the pipe running
into the vault.
In preparation to change the valves.

Apr. 6

Gunnar Ramstum and Dean Kuns
Replaced the 1 1/2" valve
and nipple at Mooney Well.

Apr. 20

Steve Fillmore, Gunnar Ramst,
Robert Sexton and Dean Kuns
Robert Sexton replaced the 3" valves
in the vaults at Canebrake & Smoketree
and Smoketree & Willow.
Dean Kuns replaced the 2" valve at
Smoketree and Willow.

Apr. 30

Read meters.

May. 6

Went to El Centro for fuel.