

Fellow Canebrakers,

On October 19th our water manager, Dean Kuns noticed the Mooney Well was not operating. In the following days he attempted to bring the well back online through electrical checks and rebooting. Error codes appeared and Dean notified me of the situation. I called Robert Sexton who previously has worked on both our Wells. Mr. Sexton contacted me three days later and I discussed the problem and gave him Dean's phone number. Mr Sexton came to the property, met Dean and decided either the pump or motor are at fault. He will arrive Wednesday and work with Dean to take necessary action to begin repairs.

As of this time both tanks are full and the Peterson well is keeping up just fine. We will keep you informed as the job progresses.

Jerry Bucheit, President
CCWD