

Water Liner References

Hulsey References

Polyurea Spray Install with Foam protection

Courtright Village Mutual water Company

POC: Jerry Smith 559-269-7543

About

- Got 6 liners: 5 water and 1 sewer
- Four 25k potable gallon, one 30k potable gallon, one sewage tank
- Cost was \$149k for 6 tanks ~5 years ago
- Installed new liners 4 years ago in 2000
- No issues yet.
- Relined old steel tanks from the 1940's
- Expected lifespan 40 years.
- Sherwin Williams (manufacturers of this liner) referred Hulsey to this water district to prep and install
- Temperature range from 0 to 80 F

Courtright assessment of Husley:

- Installed liners on schedule
- Installed liners in remote area at 8500 altitude
- Will return every 5 years to inspect and resolve any issues
- Very professional company
- Bottom Line: Would recommend to use this liner and company again

Amusement Park - Fire Suppression Tank

POC Jay Rosales 714-833-7314

About

- 18k gallon steel tank for fire suppression
- Built 1982
- Below ground
- Installed new liner in 2001

Amusement Park assessment of Husley

- Easy process
- On time delivery
- Zero issues
- Previous liner harder to remove than expected but did not charge more
- Bottom Line: Would recommend to use this liner and company again

Royal Liner References

Hung Liner Technology

Kingston Estate Winery

POC Mark Dorman 541.942.9874

About

- 1991 Steel Tank 11.5 feet diam 13 feet high
- Used for wine making to clean parts
- Water must be pristine when dealing with wine making
- Used TPO type liner vs PVC so even less chemical leaching into the water
- Installed with hoop ring on inside and hangers from the roof line
- Award winning winery so liquid storage is vital

Kingston assessment of Husley

- Flawless and painless install
- Took about 1 long day
- Handled their overflow piping very well
- Never leaked
- Will use them again on another tank soon
- Bottom Line: Would recommend to use this liner and company again