

A message from Jerry Bucheit:

Canebrake Water Customers:

Water sample results for January 2021: Jan.5th ~~ two residences, 230 Upward Trail (negative) and 230 Smoketree Ln (positive for coliform).

Department of Environmental Health requested six follow-up samples of both Wells and four residences. January 25th (5 neg) (1 pos) for coliform.365 Pincushion. Retest February 1st

365 Pincushion (neg).

The water in our system meets DEH requirements as of January 1st, 2021.

NOTE: It has been determined the positive test for coliform were due to improper testing and "new site" location 365 Pincushion which required longer line flushing due to length of service line (1,000+ feet).

Fluoride test was 3.22 mg/L which is above standard. Results and warning to public were posted at Community Center and mail pavilion. Also posted on CCWD website.

canebrakewater.specialdistrict.org

Please stay safe and enjoy your water.

Jerry Bucheit

President

CCWD