

**Water Manager's Report  
Canebrake County Water District  
January 8, 2022**

Nov. 14

Installed new battery in the golf cart.  
Ran Peterson Well.

Nov. 15

Replaced the shut off valve on meter #10

Nov. 16

Meter #47 had a slight leak between meter and service line, stopped it by tightening the fitting.

Nov. 19

Ran Peterson Well.

Nov. 20

Mario Orlando came by to take pictures  
of the Price Line to take to  
Dexter Wilson Engineering so they can draw up plans for the last section of the Price Line.  
Went to El Centro to get fuel.

Nov. 24

Ran Peterson Well.

Nov. 26

Switched to block tank.

Nov. 27

With the help of Daryl Holmes Sr.  
and Lucas Hillman we removed seven 5 gal.  
buckets of dry roots from the septic tank at the community center.

Nov. 28

Ran Peterson Well

Nov. 30

Robert Sexton came to install the new motor but found it was defective.  
Ran Peterson Well.

Dec. 1

Switched to round tank.

Dec. 2

Ran Peterson Well.

Dec. 6  
Ran Peterson Well.

Dec.13  
Robert Sexton installed the new motor, wires and sounding tube in the Mooney Well.

Dec.15  
Meter #25 had a leak between the meter and service line. I replaced the gasket.

Dec. 18  
Ran Peterson Well.

Dec. 29  
Robert Sexton hooked up the electrical to the Mooney Well. He was unable to flush and test because SDGE had the power off.

Dec. 31  
Switched to block tank.

Jan. 3  
Robert Sexton flushed and tested  
Mooney Well and did a sounding on  
Peterson Well.

Jan. 4  
Cold weather had the slip joints and compression fittings pulling apart behind Alexander's. With the help of Rob Mooney and Frank Colver we tightened everything up.  
Switched to round tank.

Jan. 6  
I took water samples and delivered them to Jerry Bucheit in El Cajon.