

## **Attachment 5: CCWD Water Manager Report Sept 18 - Nov. 12, 2022**

Sep. 18

Dean Kuns

Replaced meter #80

Meter was leaking.

Sep. 19

Ron Akey, Jerry Bucheit and Dean Kuns

Filled in the washout at Stafford Crossing  
and dragged the roads upper Canyon Rd.

Sep. 20

Ron Akey, Jerry Bucheit and Dean Kuns

Filled in more washouts on upper Canyon Rd.  
And did more dragging.

Sep. 21

Dean Kuns

Shut off Peterson Well because round tank  
was full.

Sep. 25

Dean Kuns

Repaired Stafford Crossing after the  
SDG&E trucks.

Sep. 29

Dean Kuns

Repaired Stafford Crossing again after the  
SDG&E trucks.

Filled in more washouts and dragged  
upper Canyon Rd.

Oct. 6

Dean Kuns

Set Peterson well to auto

Oct. 7

Bob Mooney and Dean Kuns

Repaired a leak at Canebrake Rd. and  
Palo Verde.

Thanks to Karyn Sauber for finding a leak on her morning walk.

Oct. 8

Dean Kuns

Ran Peterson well to raise the level of the

round tank.

Oct. 9

Ran Peterson well to raise the level of the round tank.

Oct. 12

Dean Kuns

Repaired a slight leak on the service line to  
410 Canyon Rd. and replaced the shutoff valve  
on meter # 25

Oct. 22

Ron Akey, Jerry Bucheit and Frank Colver  
Filled in washouts at the Community Center  
and the wash by Mooney Well

Oct. 31

Ron Akey, Jerry Bucheit, Ellyn Hae  
and Dean Kuns  
Dragged roads and removed rocks.  
Jerry Bucheit and Dean Kuns  
Read meters.

Nov. 5

Ran Peterson well to raise the level of the  
round tank.

Nov. 6

Jerry Bucheit and Dean Kuns  
Inspected the block tank.

Nov. 7

Robert Sexton, Jerry Bucheit and Dean Kuns  
Did soundings on Mooney well and  
Peterson well.