

## Water Manager Report November 11, 2023 by Deans Kuns

### Sep. 10

Gunnar R. and Dean Kuns  
Took water sample for full spectrum analysis.

### Sep. 30

Gunnar R., Mike Hammond ,  
Daryl Holmes Jr., Chris Macdonald,  
Stephen Fillmore, Bob Mooney and  
Dean Kuns  
Dug the trench and started hooking up  
the new tank.

### Oct. 1

Daryl Holmes Jr., Gunnar R. ,  
Chris Macdonald, Bob Mooney,  
Rob Mooney, Vie Mooney,  
Josh Kline and Dean Kuns  
Hooked a new tank to the main line.  
Gunnar and Dean took a water sample  
for the quarter.

### Oct. 2

Chris Macdonald, Bob Mooney,  
Daryl Holmes Jr. and Dean Kuns  
Replaced damaged pipe by Ann's

### Oct. 14

Chris Macdonald, Bob Mooney and  
Dean Kuns  
Repaired a leak between Stephen and Toms  
meters on Upward Trail.  
Thanks to Ron and Bonnie Akey  
For the bags of clean sand for backfill.

### Oct. 21

Had a leak near Daryl Holmes Jr.  
water meter.  
I turned off the valve across from Ron  
made the repair.  
When I tried to turn the water back on  
the valve wouldn't open.  
I got some help from Bob Mooney ,  
Rob Mooney and Kent  
We found the valve was stripped.  
Made a quick fix and turned the water on.

### Oct. 31

Read meters.

### Nov. 5

Chris Macdonald, Bob Mooney and  
Dean Kuns  
Ran water to the line between the new tank  
and the main line checked for leaks and  
started filling the tank.  
Checked 2 hrs. later and found a slight  
leak at the first fitting next to the tank.

### Nov. 6

Chris Macdonald, Bob Mooney,  
Frank Colver and Dean Kuns  
Repaired the leaking fitting with Teflon tape  
and began filling the tank.

### Nov. 7

I adjusted the transmission linkage  
on the work truck. Works good !!!

### Nov. 10

Gunnar R. , Daryl Holmes Jr. and  
Dean Kuns  
Finished filling the new tank and added  
chlorine to disinfect the tank.