

**Canebake County Water District**  
**Water Manager's Report**  
March-April 2021

Mar. 14

Dean Kuns replaced gasket between meter and shutoff on meters #21 & #24.  
Reset timers on both wells to daylight savings.

Mar. 15

Dean Kuns ran Peterson well to increase level in round tank.

Mar. 16

Dean Kuns cleared Price Line for phase 2 of pipeline.  
Switched to block tank.

Mar. 18

Dean Kuns cleared more Price Line.

Mar. 20

Dean Kuns switched to round tank.

Apr. 11

Dean Kuns ran Peterson well to increase level in round tank.

Apr. 13, 14 & 15

Ron Akey, Jerry Bucheit & Dean Kuns  
Started trench and moved rocks for phase 2 Price Line.

Apr. 17

Dean Kuns ran Peterson well to increase level in round tank.

Apr. 17 & 18

Daryl Holmes Sr, Daryl Holmes Jr, Tom Sticker, Frank Colver, Ron Akey, John Berthe,  
Ellyn Hae & Puppy, Jim Ward, Jerry Bucheit & Dean Kuns  
Dug more trench and moved more rocks.

Apr. 20

Dean Kuns switched to block tank.  
John Berthe, Jim Ward, Frank Colver, Ellyn Hae, Jerry Bucheit & Dean Kuns  
Washed pipe, moved valve and blow-off and started installing pipe.

Apr. 21

John Berthe, Jim Ward, Frank Colver, Ellyn Hae , Jerry Bucheit & Dean Kuns  
Repaired cracked fitting and installed more pipe.

Apr. 22 & 23

John Berthe, Ellyn Hae, Jerry Bucheit, Ron Akey, Dean Kuns  
Strapped pipe and covered pipe.

Apr. 23

120 Staghorn Road had an extreme drop in water pressure.

Dean Kuns investigated.

It turned out to be their pressure regulator.

Apr. 25

Daryl Holmes Jr, Cameron Faiai & his friend Scott last name unknown

Filling in trench.

Apr. 28

Dean Kuns switched to round tank

Apr. 30

Dean Kuns read meters for Mar. - Apr. 2021

May 5

Received water test results and posted them, all good.

Thanks to all the volunteers you are all a great help!!!

CCWD Water Manager

Dean Kuns