

Attachment 5: Water Manager's Report May 13th - June 9th, 2023

I would like to Thank everyone that helped tip the tank and stand it back up.

Daily Duties

- Check the level of the tank,
- Read the meters on Mooney and Peterson wells and.
- check the mail.

May 13

We tipped the tank installed the overflow and stood the tank back up.

May 14

Kim Chavez D2 Operator inspected our install and disinfection plan and everything looked good.

May 29

Had a drop in the round tank.
Natalie and I found a leak in the black poly pipe near the Holmes Jr. residence at 270 Smoketree Lane
With the help of Rob Mooney we repaired the leak.
Ran Peterson Well.

Reviewed instructions for Sounding Device