

----- Forwarded message -----

From: **Streamline** <noreply@specialdistrict.org>

Date: Tue, Oct 10, 2023 at 6:09 PM

Subject: New form submission received: Contact Us

To: <bucheitjerry@gmail.com>, <recyclingbynature@gmail.com>



CANE BRAKE COUNTY WATER DISTRICT

Contact Us

Your name: Kathy Steuermann

Your email: kjosteu@gmail.com

Subject: Water Sample analysis for new tank

First message regarding tank update gave info on timeline for water sample analysis. 2nd update doesn't but shows a clear picture of the pipe laying wide open for critters to enter and contaminate. That means bottled water, once again, for those of us living here. Can you give us a timeline of when analysis will be done? And will it be done again in a month to make sure that the line has not been contaminated? Thank You

Message:

Attachment:

[Reply / Manage](#)

Powered by [Streamline](#).

Response:

On Wed, Oct 11, 2023 at 7:26 PM Eilyn Hae <recyclingbynature@gmail.com> wrote: Kathy,

We dropped off the water sample for full analysis on September 11, 2023. It will take about 4 weeks so we should have the results before the next board meeting. This will also include pesticides, herbicides, Coliform, and eColi. About 100 items tested.

If you look closely, you can see that the picture sent as part of the update shows the pipes laying in the ditch before they were connected. They were connected after this picture was taken and a rag has sealed the end of the pipe since that day. At no time were they open for critters to enter. However, just want to let you know as part of our protocol, we will chlorinate, flush, and sample the water for e coli and coliform before

putting it on line (It will not be a full spectrum analysis). We will know more about the timeline for putting the water tank on the system after the work this weekend.

Ellyn
CCWD

Kathy Steueremann <kjosteu@gmail.com>

Thu, Oct
12,
1:21 PM

to me

OK., then I'll take a sample in myself. Thank You