

**Canebrake County Water District**  
**General Manager's Report**  
September 11, 2021

Jun. 13

Switched to round tank.

Jun. 28

Compression fitting leak behind Alexanders.

Straightened the pipe and tightened the fittings. Water was off about 2hrs.

Jun. 30

Read water meters.

July 4

Ran Peterson well to bring up level  
of round tank.

July 25

Went to El Centro for fuel.

Aug. 10

Straightened pipe and tightened fittings  
behind Alexanders.

Aug. 13

Installed a clean out on septic line at the community center and ran the snake through it with help  
from Jerry Bucheit, Daryl Holmes Sr.  
and Daryl Holmes Jr.

Aug. 20

Switched to the block tank.

Aug. 24

Switched to the round tank.

Aug. 31

Read water meters.

Sep. 1

Repaired a cracked fitting behind Alexanders.

Sep. 2

We had a visit from Mario Orlando from Spears.

He came and looked at our new line and gave us some technical advice.

He is a very nice guy and very knowledgeable.

Sep. 6

Measured the remaining length of the

Price Line and counted the remaining pipe.

The remaining length is 1,100 feet and we have just over that in pipe.