

Canebrake County Water District
Water Manager's Report, June 11, 2022

May 16

Dean Kuns

Made some adjustments to the Price Line.

May 22

Dean Kuns

Shut off the Peterson well. The level was getting to high for this time of year.

May 25

Dean Kuns

Took water samples and delivered them to Jerry Bucheit in El Cajon.

May 27

Dean Kuns installed the carburetor on the dump truck.

May 30

Dean Kuns

Tried to hook up the carburetor on the dump truck and had a few issues.

The threaded rod for the air filter was too short and the hole where the linkage hooks up was too small. Daryl Sr. Will get a longer rod for the air filter. Thanks to Daryl Sr. and Jr. for supplying parts for the dump truck. Also ran the generator and it's working good.

May 31

Water sample results showed coliform.

June 1

Dean Kuns

Took another water sample and delivered to Jerry Bucheit.

June 2

Second water sample came back with coliform.

June 6

Jerry Bucheit and Dean Kuns

Took several water samples to try and isolate the contamination.

June 8

Dean Kuns

Ran Peterson well to raise the level of the round tank to treat the water with chlorine. Poured chlorine into the tank and opened the blowoff to start pulling the treated water into the line.

June 9

Jerry Bucheit and Dean Kuns

Went around opening blowoffs to pull the

treated water into the system.

June 10

Jerry Bucheit and Dean Kuns

Went to El Centro to get more chlorine and fuel.

And went around opening blowoffs to pull more treated water into the system then turned on Peterson well to refill the tank.

CCWD Water Manager

Dean Kuns